

TEST RESULTS

Monroe City routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2016. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
MICROBIOLOGICAL CONTAMINANTS							
Total Coliform Bacteria	N	0	N/A	0	5	2016	Naturally present in the environment
Fecal coliform and <i>E.coli</i>	N		N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	2016	Human and animal fecal waste
Turbidity for Ground Water	N	0.07-1.5	NTU	N/A	5	2016	Soil Runoff
INORGANIC CONTAMINANTS							
Arsenic	N	1-1.2	ppb	0	10	2016	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	0.011-0.024	ppm	2	2	2016	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a. 1.3 b. 0	ppm	1.3	AL=1.3	2016	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide	N	0-2	ppb	200	200	2016	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Fluoride	N	0.2-0.3	ppb	4	4	2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. 2.4 b. 0	ppb	0	AL=15	2016	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen)	N	0.2-0.3	ppm	10	10	2016	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	0-0.6	ppb	50	50	2016	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	5-6.2	ppm	500	None	2016	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	12-22	ppm	1000	1000	2016	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
TDS (Total Dissolved Solids)	N	104-158	ppm	2000	2000	2016	Erosion of natural deposits
RADIOACTIVE CONTAMINANTS							
Alpha emitters	N	0-1.9	pCi/l	0	15	2016	Erosion of natural deposits
Radium 228	N	0.01-0.47	pCi/l	0	5	2016	Erosion of natural deposits



LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Monroe City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at: <http://www.epa.gov/safewater/lead>.

TABLE DEFINITIONS

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND)

Laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l)

One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l)

One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL)

The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level (MRDL)

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that ad

ND/Low - High

For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Picocuries per liter (pCi/L)

picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU)

Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Treatment Technique (TT)

A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level Goal (MCLG)

The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

BACKFLOW PROTECTION

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health.



So, what can you do?

Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help. **435-527-4621**



POTENTIAL HEALTH CONCERNS


All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or manmade. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their healthcare providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.



10 North Main
Monroe City, Utah 84754



Postal Patron

Monroe City, UT 84754



WATER CONSERVATION TIPS

Water Conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but you can also save money by reducing your water bill. Here are a few suggestions

Conserve in the home


- Take Shorter Showers
- Run the dishwasher only when full.
- Soak dishes before washing
- Fix leaking faucets, pipes, toilets etc.
- Wash full loads of laundry
- Replace old fixtures that no longer work
- Do not use the toilet for trash disposal
- Install water saving devices for faucets and appliances

Conserve Outdoors

- Water the lawn and garden in the early morning or evening.
- Use mulch around plants and shrubs.
- Repair leaks in faucets and hoses.
- Use water-saving nozzles.
- Use water from a bucket to wash your car and save the hose for rinsing.
- Shutoff your sprinklers manually or use a rainfall shutoff device when it rains.

CONSERVE H₂O

SLOW THE FLOW



2016 Drinking Water Quality Report Monroe City

This report shows our water quality and what it means to you our customer.

We are pleased to report that our drinking water meets federal and state requirements.



JOIN US

If you want to learn more, please attend any of our regularly scheduled city council meetings. They are held on the **second and fourth** Tuesday of each month at the city office:

10 North Main: The meetings will begin at 7:30 p.m.

If you have any questions about this report or concerning your water utility, please contact Monroe City **435-527-4621.**

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second and fourth Tuesday of each month at the city office, 10 north Main. Meeting begins at 7:30 pm.

MESSAGE TO OUR CUSTOMERS

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water sources have been determined to be from ground water under the direct influence of surface water. We treat the water through a Microfiltration Treatment Plant.

SOURCE PROTECTION

The Drinking Water Source Protection Plan for Monroe City is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a medium level of susceptibility from potential contamination from sources such as surface water source. There are no other potential contamination sources because of where the spring is located. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

WATER SYSTEM MAINTENANCE

Monroe City is committed to ensuring a high quality of drinking water along with the best possible service to our customers.

** Certified Operators & City Personnel*

We have certified water operators and city personnel who work hard to provide a sustainable and clean water supply to our customers.

** Distribution System*

The City's water department maintains a distribution system of approximately 36 miles of water mains with 142 fire hydrants and 931 water service connections.

We at Monroe City work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.